

No. 4.—RETURN of NOTICES given to REPAIR BOILERS during the Financial Year ended the 31st March, 1895.

No.	Type.	Description of Repairs.
3	Cornish	Extra stays and gusset-stays riveted.
2	"	New end and new angle-iron.
10	"	Strengthening hoops round furnace.
1	"	Dome stayed.
3	"	Patches on shell under blow-off cock.
2	"	Water-gauge mountings.
2	"	Shell-plates in bottom renewed.
2	"	Landing in shell-plate caulked and riveted.
2	Cylindrical	Longitudinal stays renewed.
1	Fire-engine	Retubed.
2	Lancashire	Strengthening hoops on furnace.
2	Locomotives	Renewed rivets in fire-box.
2	"	Longitudinal stays renewed.
2	"	Stripped, tubes drawn, repaired, and tested.
2	"	Stripped and tested.
1	"	Throat-plate renewed.
1	"	Tube-plate patched.
3	"	Renewed tube-plate.
2	"	Stays in fire-box.
1	"	Skirt fire-box renewed.
1	"	Rivets in fire-box renewed.
3	"	Plug-holes fitted with sockets and new plugs.
1	Marine	Patch under blow-off cock and shell sheathed.
2	"	Patches in furnace.
1	"	Stays in combustion-chamber
7	Multitubular	New plate over fire.
7	"	Patches over fire cut out, renewed, and riveted.
1	"	Tube-plate renewed.
6	"	Compensating-ring round manhole-opening.
3	"	Longitudinal stays renewed.
3	"	Extra longitudinal stays and stay-tubes fitted.
4	"	Retubed.
2	"	Partially retubed.
3	"	Renewed brickwork setting.
2	"	Recaulked seams over fire.
2	"	Protected blow-off pipes from fire.
2	"	Gusset-stays renewed.
4	"	Gusset-stays riveted.
2	"	Mud-drain renewed.
3	Portable	Renewed fire-box.
4	"	Renewed crown of fire-box.
16	"	Fire-boxes patched.
12	"	Fire-box stays renewed.
2	"	Tube-plates renewed.
10	"	Retubed.
5	"	Partially retubed.
9	"	Shell patched.
4	"	Girders on fire-box renewed.
6	"	Longitudinal stays renewed.
1	"	Saddle-plate renewed.
6	"	Stripped for examination.
10	"	Patches round mud-doors.
12	"	Spring-balances to renew
2	"	Tubes expanded.
4	"	Mud-doors renewed.
3	"	Skirt of fire-box and foundation-engine renewed.
13	"	Steam-gauges renewed.
2	"	Blow-off cocks renewed.
16	"	Fusible plugs renewed.
2	Semiportable	Longitudinal stays renewed.
1	"	Extra stays in tube-space.
2	"	Compensating-ring round manhole-opening.
2	"	Mud-doors renewed.
2	"	Girder-stays renewed.
1	Semitubular	Shell repaired.
1	"	Gusset-stays renewed.
1	"	Strengthening hoops on furnace.
1	"	Retubed.
1	"	New angle-iron connecting furnace to shell.