

TABLE I.—ELECTRIC-SUPPLY STATIONS OF NEW ZEALAND AT 31st MARCH, 1921.

Station.	Ownership.	Population supplied.	Number of Consumers.	Capacity in Kilowatts.		Units generated or purchased.	Units sold or used.	Units non-productive.	Per Cent. of Non-productive Units.	System of Supply.	Supply Voltage.	Static Head, in Feet.	Route-miles of Lines.
				Main Plant.	Stand-by Plant.								
Steam Stations.													
1. Auckland (lighting) (tramways)...	City	108,000	6,180	6,500	..	4,148	13,046,420	10,496,060	19.5	D.C. & A.C.	460/400/230	..	90.0
2. Wellington (lighting) (tramways)	City	92,300	12,242	3,500	..	5,950	13,191,365	13,191,365	..	D.C.	550	..	..
3. Invercargill	Borough	24,000	418	4,000	..	3,000	8,402,670	6,530,220	22.0	A.C.	105 S.P.	..	190.0
4. Gisborne	Borough	14,477	1,762	975	..	3,180	12,272,808	11,064,596	10.0	D.C.	550	..	..
5. Hamilton	Borough	11,439	634	350	300 (oil)	630	2,310,450*	1,908,388	17.4	A.C.	400/230	..	74.5
6. Huntly	Town Board	2,500	277	170	..	410	1,087,105*	858,863	20.9	D.C.	440/220	..	33.0
7. Bluff	Borough	1,599	270	225	..	185	416,575†	333,259	20.0	D.C.	460/230	..	34.0
8. Kaitangata	Borough	1,681	270	50	..	37	62,753	49,125	21.7	D.C.	460/230	..	7.0
Totals	..	255,996	23,509	21,820	300	5	50,848,365	44,478,349	20.1	A.C.	460/230	..	6.5
Gas Stations.													
1. Napier	Borough	15,000	2,000	850	100 (oil)	620	1,627,696*	1,420,667	16.9	..	..	..	437.0
2. Wanganui	Borough	16,492	24	485	..	290	759,735*	123,000†	12.7	D.C.	460/230	..	27.5
3. Timaru	Borough	14,500	1,048	425	..	300	934,000	525,106	..	D.C.	550	..	2.0
4. Ashburton	Company	6,172	710	186	165 (oil)	205	480,441	384,352†	43.5	D.C.	460/230	..	46.0
5. Devonport	Company	9,304	1,067	200	..	190	551,300	407,765	20.0	D.C. & A.C.	400/230	..	62.6
6. Feilding	Borough	4,500	897	160	150 (oil)	148	318,342	274,321	26.0	D.C.	460/230	..	18.0
7. Te Kuiti	Borough	2,240	440	180	..	86	198,210	166,622	13.8	A.C.	230 S.P.	..	24.2
8. Picton	Borough	1,371	250	82.5	7.5 (water)	72	157,680†	126,144†	16.0	D.C.	460/230	..	10.0
9. Pukekohe	Borough	1,890	280	74.0	..	79	56,740†	45,393	20.0	D.C.	460/230	266	9.0
10. Waitara	Borough	1,500	305	62	23 (water)	66	96,200	63,070	20.0	D.C.	460/230	..	6.3
11. Opoiki	Private	1,150	250	86	..	55	68,128	55,672	34.4	D.C.	460/230	..	8.0
12. Winton	Borough	600	146	53	..	25	23,718	19,339	18.3	D.C.	460/230	..	10.0
13. Waioa	Borough	1,915	310	56	..	60	85,498	73,888	18.0	A.C.	400/230	..	4.0
14. Ngauwahia	Borough	1,120	185	70	..	31	64,656	38,438	13.6	D.C.	460/230	..	6.5
15. Martinborough	Town Board	932	210	27.5	..	31	68,395	42,639	40.5	D.C.	460/230	..	7.0
16. Pahiatua	Borough	1,340	189	85	..	45	45,171	41,909	37.7	D.C.	230	..	10.0
17. Eketahuna	Borough	1,874	205	62.5	7.5 (water)	30	41,300	29,870	7.0†	D.C.	460/230	..	9.2
18. Bulls	Private	580	140	27	..	24	25,975	18,702	29.0	D.C.	230	230	5.0
19. Waikuku	Town Board	730	96	23.5	..	22	13,343	12,291	28.0	D.C.	230	..	5.0
Totals	..	82,210	8,752	3,195.0	453	2,379	5,616,528	3,869,188	7.9†	D.C.	460/230	..	4.0
274.3													
Oil Stations.													
1. Hastings	Borough	9,106	2,000	575	..	344	1,254,662	1,119,456	23.0	..	..	..	35.0
Haylock North	Town Board	1,176	240	Bulk supply	..	(31)	59,065	53,583	10.8	D.C.	460/230	..	11.0
2. Stratford	Borough	3,100	1,003	145	90 (water)	186	363,040	239,285	9.3†	A.C.	400/230	..	24.0
Totals	..	13,382	3,243	720	90	530	1,676,767	1,412,324	34.1	A.C.	250/100 S.P.	27	24.0
70.0													

* Including tramways.

† Assessed from incomplete returns.

‡ Assessed by local authority, excluding tramways.